



Certificate of Suitability

Certificate No.: SAA183460

Certificate Holder: Shenzhen Growatt New Energy Technology Co.,Ltd
1st East & 3rd Floor of Building A, Building B,
Jiayu Industrial Park, #28, GuangHui Road,
LongTeng Community, Shiyan Street, Baoan District,
Shenzhen,
P.R. China

Class Description: Non-Declared
Product Description: AC Coupled Inverter
Brand Name: Growatt
Model No.: SPA 3000TL BL
Markings: Grid: 230V~ 50Hz 16A 3000VA
Stand alone output: 230V~ 50Hz 3000W
Battery: 42-59Vdc charge/discharge 66/66A
-25°C to +60°C, IP65, Class I

Standard: AS 62040.1.1:2003
AS/NZS 4777.2:2015

Conditions: Nil

Certification Mark: SAA183460 or RCM

Date First Registered: 10 December 2018
Date of Expiry: 10 December 2023


For and on Behalf of
SAA Approvals Pty Ltd




SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register

Issued: 10-12-18 183460/1



10 December 2018

Shenzhen Growatt New Energy Technology Co.,Ltd
1st East & 3rd Floor of Building A, Building B,
Jiayu Industrial Park, #28, GuangHui Road,
LongTeng Community, Shiyan Street, Baoan District,
Shenzhen,
P.R. China

C/- Intertek Testing Services Shenzhen Ltd Guangzhou

Dear Sir

**Certificate of Suitability – SAA183460
AC Coupled Inverter
Model No.: SPA 3000TL BL**

We are pleased to advise that your application for certification of the above electrical product has been successful.

Please ensure that you keep the enclosed Certificate in a safe place as it is your evidence that the product has been certified.

The certified product must now be marked with the SAA Number SAA183460 or may be marked with the Regulatory Compliance Mark (RCM). The RCM must be used in accordance with the conditions set out in the relevant parts of AS/NZS 4417.

Please note that if the electrical product is modified in any way or your company details change you are required to notify this office of the details of the modification. You can either download the required form from our web page or contact our office.

As part of our operational guidelines we are required to check that a certified product remains compliant during the term of the Certificate. At some stage during this term we may request a sample for evaluation.

If you need any further information or need to discuss this letter please don't hesitate to contact our office.

Yours sincerely

A handwritten signature in black ink, appearing to be the initials 'JH'.

**For and on behalf of
SAA Approvals Pty Ltd**

ABN 91 125 451 327

P +61 7 3393 9455

F +61 7 3393 9499

E info@saaapprovals.com.au

W www.saaapprovals.com.au

PO Box 189, Cannon Hill QLD 4170
5/20 Rivergate Place, Murarrie QLD 4172



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA183460

Date of Issue: 10 December 2018

Class Description: Non-Declared
Product Description: AC Coupled Inverter

Additional Models

SPA 1000TL BL

Description

Grid: 230V~ 50Hz 6A 1000VA
Stand alone output: 230V~ 50Hz 1000W
Battery: 42-59Vdc charge/discharge 24/24A

SPA 2000TL BL

Grid: 230V~ 50Hz 10A 2000VA
Stand alone output: 230V~ 50Hz 2000W
Battery: 42-59Vdc charge/discharge 44/44A


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 12-12-18 183460/2a
Rating corrected